

4725.5050 PRIMING WATER-SUPPLY WELL PUMPS.

A pump that requires priming for ordinary use must not be installed on a water-supply well unless the well is only used for a water irrigation system. An irrigation well pump must be primed only with water free of contamination and carrying a measurable chlorine residual. An irrigation well equipped with a centrifugal pump may be primed without chlorination when the pump is filled with water taken directly from the well.

Statutory Authority: *MS s 103I.101; 103I.221; 103I.301; 103I.621; 144.05; 144.12; 144.383; 157.04; 157.08; 157.09; 157.13*

History: *17 SR 2773; 33 SR 211*

Published Electronically: *September 2, 2008*