

**4731.6080 FIRE PROTECTION.**

For panoramic irradiators, the radiation room must have:

A. heat and smoke detectors, which must activate an audible alarm. The alarm must be capable of alerting a person who is prepared to summon assistance promptly;

B. a system whereby the sources automatically become fully shielded if a fire is detected; and

C. a fire extinguishing system capable of extinguishing a fire without the entry of personnel into the room. The system for the radiation room must have a shut-off valve to control flooding into unrestricted areas.

**Statutory Authority:** *MS s 144.1202; 144.1203*

**History:** *29 SR 755*

**Published Electronically:** *March 12, 2009*