

7011.0545 TABLE I: EXISTING INDIRECT HEATING EQUIPMENT.

| RATED HEAT INPUT OF THE INDIRECT HEATING EQUIPMENT | RATED HEAT INPUT OF ALL DIRECT AND INDIRECT HEATING EQUIPMENT AT THE PARTICULAR LOCATION | EMISSION LIMITATIONS | | |
|--|--|----------------------|-------------|--------------|
| | | Particulate Matter | Solid Fuels | Liquid Fuels |
| Million BTU/Hr. | Million BTU/Hr. | All Fuels | Solid Fuels | Liquid Fuels |
| A. Within Minneapolis-St. Paul Air Quality Control Region | | | | |
| Greater than 250 | Greater than 250 | 0.4 | 3.0 | 1.6 |
| Less than or equal to 250 | Greater than 250 | 0.4 | 3.0 | 1.6 |
| Less than or equal to 250 | Less than or equal to 250 | 0.4 | 4.0 | 2.0 |
| B. Within the City of Duluth | | | | |
| Greater than 250 | Greater than 250 | 0.4 | 4.0 | 2.0 |
| Less than or equal to 250 | Greater than 250 | 0.4 | 4.0 | 2.0 |
| Less than or equal to 250 | Less than or equal to 250 | 0.4 | N.A.* | N.A. |
| C. Outside Minneapolis-St. Paul Air Quality Control Region and Outside the City of Duluth | | | | |
| Greater than 250 | Greater than 250 | 0.6 | 4.0 | 2.0 |
| Less than or equal to 250 | Greater than 250 | 0.6 | 4.0 | 2.0 |
| Less than or equal to 250 | Less than or equal to 250 | 0.6 | N.A. | N.A. |

*N.A.—Not applicable

Statutory Authority: *MS s 116.07*

History: *18 SR 614*

Published Electronically: *February 25, 2008*