

7011.0550 TABLE II: NEW INDIRECT HEATING EQUIPMENT.

RATED HEAT INPUT OF THE INDIRECT HEATING EQUIPMENT Million BTU/Hr.	RATED HEAT INPUT OF ALL DIRECT AND INDIRECT HEATING EQUIPMENT AT THE PARTICULAR LOCATION Million BTU/Hr.	EMISSION LIMITATIONS LBS. PER MILLION BTU							
		Particulate Matter All Fuels	Solid Fuels	Liquid Fuels	Solid Fuels	Gaseous Fuels	NO _x *	Liquid Fuels	Liquid Fuels
A. Within Minneapolis-St. Paul Air Quality Control Region									
Greater than 250	Greater than 250	0.1	1.2	0.8	0.7	0.2	0.2	0.3	0.3
Greater than 100 but less than or equal to 250	Greater than 250	0.1	3.0	1.6	N.A.**	N.A.	N.A.	N.A.	N.A.
Less than or equal to 100	Greater than 250	0.4	3.0	1.6	N.A.	N.A.	N.A.	N.A.	N.A.
Less than or equal to 250	Less than or equal to 250	0.4	4.0	2.0	N.A.	N.A.	N.A.	N.A.	N.A.
B. Within the City of Duluth									
Greater than 250	Greater than 250	0.1	1.2	0.8	0.7	0.2	0.2	0.3	0.3
Greater than 100 but less than or equal to 250	Greater than 250	0.1	4.0	2.0	N.A.	N.A.	N.A.	N.A.	N.A.
Less than or equal to 100	Greater than 250	0.4	4.0	2.0	N.A.	N.A.	N.A.	N.A.	N.A.
Less than or equal to 250	Less than or equal to 250	0.4	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.
C. Outside Minneapolis-St. Paul Air Quality Control Region and Outside the City of Duluth									
Greater than 250	Greater than 250	0.1	1.2	0.8	0.7	0.2	0.2	0.3	0.3
Less than or equal to 250	Greater than 250	0.4	4.0	2.0	N.A.	N.A.	N.A.	N.A.	N.A.
Less than or equal to 250	Less than or equal to 250	0.4	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.	N.A.

*NO_x expressed as NO₂
 **N.A.—Not applicable

Statutory Authority: *MS s 116.07*

History: *18 SR 614*

Published Electronically: *February 25, 2008*