

7017.1035 TESTING REQUIRED.

The owner or operator of an emission facility shall arrange to conduct a relative accuracy test audit, cylinder gas audit, or calibration error audit as required to determine the accuracy of a continuous monitoring system at times requested by the commissioner.

Statutory Authority: *MS s 116.07*

History: *23 SR 1764*

Published Electronically: *November 29, 2007*