

**7045.0305 STANDARDS FOR GENERATORS WHO SEWER HAZARDOUS WASTE.**

Subpart 1. **Applicability.** This part applies to generators who discharge their own hazardous waste to a sanitary sewer.

Subp. 2. **Generator size determination.** A generator who sewers hazardous waste shall include the quantity of sewered hazardous waste in their size determination under part 7045.0206 except for the volume of a hazardous waste that has been pretreated provided that:

A. an 80 percent reduction of the quantity of the hazardous waste constituent mass is achieved before sewerage;

B. the discharge is approved by a publicly owned treatment works permitted under part 7001.0520, subpart 3, item B;

C. the generator is licensed to sewer their waste under parts 7045.0225 to 7045.0250; and

D. the generator has met the conditions of part 7001.0520, subpart 3, item C.

Subp. 3. **Management.** A generator who sewers hazardous waste shall comply with the requirements of this chapter applicable to their generator size with the following exception. A generator whose quantity determination is zero because the generator meets the conditions of subpart 2 will be classified as a very small quantity generator and shall meet the requirements of this chapter that apply to very small quantity generators.

**Statutory Authority:** *MS s 116.07*

**History:** *16 SR 2102*

**Published Electronically:** *October 10, 2013*