

7151.6500 SUBSTANCE TRANSFER AREAS.

Subpart 1. **General.** Owners and operators shall provide, for all tank systems, substance transfer safeguards such as spill boxes, remote fill boxes, or containment areas. The safeguards must effectively contain a release at the connection point, as well as at the vehicle, during transfer of the substance to and from the tank.

Subp. 2. **Exclusions.** A substance transfer area is not required for:

- A. a tank that is filled with a hand-held nozzle;
- B. a transfer of the substance through a continuous pipeline between tanks at one site; or
- C. a barge transfer facility regulated under United States Coast Guard regulations, Code of Federal Regulations, title 33, parts 126, 154, and 156.

Subp. 3. **Timing of compliance.** Owners and operators shall comply with subpart 1 after one year following November 2, 1998.

Statutory Authority: *MS s 115.03*

History: *23 SR 883*

Published Electronically: *October 2, 2007*