

7151.9100 INADEQUATE SAFEGUARDS.

The owner or operator shall immediately remove a substance from an aboveground storage tank failing to meet the requirements of this chapter. The owner or operator shall refrain from further use of the aboveground storage tank until the tank or tank system complies with all applicable requirements of this chapter.

Statutory Authority: *MS s 115.03*

History: *23 SR 883*

Published Electronically: *October 2, 2007*