

**7511.0704 SECTION 704, FLOOR OPENINGS AND SHAFTS.**

IFC Section 704 is amended by adding a section to read:

**704.3 Compliance alternative.** Protection of vertical openings that do not serve as part of the required means of egress conforming to the requirements of NFPA 101 (Life Safety Code) shall be deemed to be in compliance with this code.

**Statutory Authority:** *MS s 299F.011*

**History:** *32 SR 10*

**Published Electronically:** *October 11, 2007*