

**7511.0915 SECTION 915, CARBON MONOXIDE DETECTION.**

Subpart 1. **IFC section 915.1.1.** IFC section 915.1.1 is amended by adding an exception to read:

**Exception:** In multifamily dwellings, approved and operational carbon monoxide alarms may be installed between 15 and 25 feet of carbon monoxide-producing central fixtures and equipment provided there is a centralized alarm system or other approved mechanism for responsible parties to hear the alarms at all times.

Subp. 2. **IFC section 915.2.** IFC section 915.2 and subsections 915.2.1 and 915.2.2 are amended to read as follows:

**915.2 Locations.** Where required by Section 915.1.1, carbon monoxide detection shall be installed in the locations specified in Sections 915.2.1 through 915.2.3.

**915.2.1 Dwelling units.** Carbon monoxide detection shall be installed in dwelling units outside of each separate sleeping area within 10 feet of the bedrooms. Where a fuel-burning appliance is located in a bedroom or its attached bathroom, carbon monoxide detection shall be installed within the bedroom.

**915.2.2 Sleeping units.** Carbon monoxide detection shall be installed in sleeping units.

**Exception:** Carbon monoxide detection shall be allowed to be installed outside of each separate sleeping area within 10 feet of the sleeping unit where the sleeping unit or its attached bedroom does not contain a fuel-burning appliance and is not served by a forced air furnace.

(Section 915.2.3 remains unchanged.)

**Statutory Authority:** *MS s 326B.02*

**History:** *44 SR 610*

**Published Electronically:** *April 16, 2020*