

**7511.1015 SECTION 1015, EXIT AND EXIT ACCESS DOORWAYS.**

IFC Section 1015.1 is amended to read:

**1015.1 Exit or exit access doorways required.** Two exits or exit access doorways from any space shall be provided where one of the following conditions exists:

1. The occupant load of the space exceeds the values in Table 1015.1.

**Exception:** In Groups R-2 and R-3 occupancies, one means of egress is permitted within and from individual dwelling units with a maximum occupant load of 16 if the dwelling unit is equipped throughout with an automatic sprinkler system in accordance with Section 903.3.1.1 or 903.3.1.2.

2. The common path of egress travel exceeds the limitations of Section 1014.3.

3. Where required by Sections 1015.3, 1015.4, and 1015.5.

4. When located in buildings used for educational purposes, laboratories and prep rooms that exceed 500 square feet in area and contain hazardous materials.

**Exception:** Group I-2 occupancies shall comply with Section 1014.2.2.

**Statutory Authority:** *MS s 299F.011*

**History:** *32 SR 10*

**Published Electronically:** *October 11, 2007*