

7511.2007 SECTION 2007, HELISTOPS AND HELIPORTS.

IFC section 2007.5 is amended to read:

2007.5 Standpipe systems. A building with a rooftop helistop or heliport shall be provided with a Class 1 standpipe system extended to the roof level on which the helistop or heliport is located. All portions of the helistop and heliport area shall be within 150 feet (45,720 mm) of a 2-1/2 inch (63.5 mm) outlet on the standpipe system.

Statutory Authority: *MS s 326B.02*

History: *44 SR 610*

Published Electronically: *April 16, 2020*