

**7835.5200 ISOLATION OF GENERATOR.**

Each qualifying facility must have a lockable, manual disconnect switch capable of isolating the generator from the utility's system readily accessible to the utility.

**Statutory Authority:** *MS s 216A.05; 216B.08; 216B.164*

**History:** *9 SR 993*

**Published Electronically:** *February 28, 2000*