

7835.5500 MAINTAINING POWER OUTPUT.

The power output of the qualifying facility must be maintained so that frequency and voltage are compatible with normal utility service and do not cause that service to fall outside the prescribed limits of commission rules and other standard limitations.

Statutory Authority: *MS s 216A.05; 216B.08; 216B.164*

History: *9 SR 993*

Published Electronically: *February 28, 2000*