

**7853.0030 SCOPE OF RULES.**

Each petroleum supplier applying for a certificate of need for one of the following types of large energy facilities shall provide all information required by this chapter:

- A. a new large LPG storage facility;
- B. a new large petroleum pipeline facility;
- C. any project that, within a period of one year, would expand the LPG storage capacity of an existing LPG storage facility in excess of either 20 percent of capacity of 100,000 gallons, whichever is greater; and
- D. any project that, within a period of two years, would expand an existing large petroleum pipeline in excess of either 20 percent of its rated capacity or 10,000 barrels per day, whichever is greater.

Exception: any person who as of the effective date of this chapter has begun or has completed construction of a large energy facility is not subject to this chapter for that facility.

**Statutory Authority:** *MS s 216B.08; 216B.2421; 216B.243; 216C.10*

**History:** *L 1983 c 289 s 115; 26 SR 1438*

**Published Electronically:** *November 14, 2003*