

CHAPTER 299F

FIRE MARSHAL

299F.011	Uniform fire code; adoption.	299F.451	Fire alarm systems; definitions.
299F.361	Installation of fire extinguishers in multiple unit residential buildings.	299F.57	Safety standards; gas pipelines.
299F.362	Smoke detection devices; installation; penalty.	299F.641	Intrastate hazardous liquid pipelines.
		299F.72	Definitions.

299F.011 UNIFORM FIRE CODE; ADOPTION.

[For text of subs 1 to 4b, see M.S.1990]

Subd. 4c. **Exit sign illumination.** The uniform fire code must prohibit the use of incandescent bulbs, except for battery-powered back-up bulbs, in internally illuminated exit signs.

[For text of subs 5 to 6, see M.S.1990]

History: 1991 c 149 s 3; 1991 c 235 art 3 s 2

NOTE: Subdivision 4c, as added by Laws 1991, chapter 149, section 3, is effective January 1, 1994, and applies to all internally illuminated exit signs in use on or after that date. See Laws 1991, chapter 149, section 5.

299F.361 INSTALLATION OF FIRE EXTINGUISHERS IN MULTIPLE UNIT RESIDENTIAL BUILDINGS.

Subdivision 1. **Standards.** There shall be provided and installed in each apartment of a multiple unit residence building containing four or more apartments, at least one fire extinguisher complying with the standards prescribed by the state fire code and with a rating of not less than 1A-10BC, as defined by the National Fire Protection Pamphlet No. 10, or there shall be provided and installed within 50 feet of each apartment entrance at least one fire extinguisher complying with the standards prescribed by the state fire code and with a rating of not less than 2A-10BC as defined by the National Fire Protection Pamphlet No. 10.

[For text of subs 2 and 3, see M.S.1990]

History: 1991 c 199 art 2 s 23

299F.362 SMOKE DETECTION DEVICES; INSTALLATION; PENALTY.

[For text of subs 1 to 7, see M.S.1990]

Subd. 8. [Repealed, 1991 c 199 art 1 s 67]

[For text of subs 9 and 10, see M.S.1990]

299F.451 FIRE ALARM SYSTEMS; DEFINITIONS.

Subdivision 1. **Scope.** Except where the context requires otherwise, the terms defined in subdivisions 2 and 3 have the meanings given them.

[For text of subs 2 and 3, see M.S.1990]

History: 1991 c 199 art 1 s 68

299F.57 SAFETY STANDARDS; GAS PIPELINES.

[For text of subd 1, see M.S.1990]

Subd. 1a. **Adoption of federal standards.** The federal safety standards adopted as Code of Federal Regulations, title 49, parts 191, 192, 193, and 199, and standards that may be adopted that amend parts 191, 192, 193, and 199, are adopted as minimum safety standards.

[For text of subs 3 to 5, see M.S.1990]

History: 1991 c 233 s 95

299F.641 INTRASTATE HAZARDOUS LIQUID PIPELINES.

[For text of subd 1, see M.S.1990]

Subd. 2. Federal standards adopted. The federal safety standards adopted as Code of Federal Regulations, title 49, parts 195 and 199, and standards that may be adopted that amend parts 195 and 199, are adopted as minimum safety standards. The commissioner may by rule adopt additional or more stringent safety standards for intrastate hazardous liquid pipeline facilities and the transportation of hazardous liquids associated with those facilities, if the state standards are compatible with the federal standards. The standards may not prescribe the location or routing of a pipeline facility.

[For text of subds 3 to 8, see M.S.1990]

History: 1991 c 233 s 96

299F.72 DEFINITIONS.

Subdivision 1. Scope. For the purposes of sections 299F.71 to 299F.83; 609.48, subdivision 4; 609.52, subdivision 3; 609.561; 609.562; 609.563; and 609.713, the terms defined in this section have the meanings given them.

[For text of subds 2 to 4, see M.S.1990]

History: 1991 c 199 art 1 s 69