

326B.962 TESTS.

In subjecting both high- and low-pressure boilers and pressure vessels to the hydrostatic test, and to determine the safe allowable working pressure, the inspector shall use the latest approved formula of the ASME Code or National Board Inspection Code, as applicable.

History: (5482) *RL s 2176; 1957 c 503 s 9; 1982 c 379 s 8; 2007 c 140 art 9 s 6,27; art 13 s 4*